

Number	19-004132-PR01 (NW 1-E03-020310-en-02)
Owner	MOLL bauökologische Produkte GmbH Rheintalstr. 35-43 68723 Schwetzingen Germany
Product	Internal and external joint sealing system between window and building structure
Designation	Shipping name: Joint sealing tape CONTEGA SOLIDO IQ
Details	Installation conditions Masonry perforated brick with stump reveal, reveal plastered and painted; window wooden window IV68, 1,230 mm x 1,480 mm with glass configuration $\underline{4} / 16 / \underline{4}$ , centred in the reveal; fixing screws, lateral and at top, fixing distance $\leq 700$ mm; lateral securing by lateral screws and transverse spacer blockings; load transmission spacer blockings at bottom
Special features	Watertightness test without internal sealing level.
Result	

Valuation of joint-properties according to ift-guideline MO-01/1:2007-01 - section 5.4 (detail results on page 2)




**Requirement: fulfilled**

ift Rosenheim

01.07.2020



Thomas Stefan, Dipl.-Ing. (FH)  
Head of Testing Department  
Building Component Testing



Martin Heßler, Dipl.-Ing. (FH)  
Project Engineer  
Building Component Testing

## Basis \*)


ift-Richtlinie MO-01/1:2007-01  
\*) and corresponding national versions  
e.g. DIN EN)

Test report: 19-004132-PR01 PB  
1-E03-020310-de-02

Replaces ift-Nachweis:

19-004132-PR01 NW 1-E03-  
020310-en-01 dated 31.03.2020.

## Representation



## Instructions for use

The results obtained can be used as evidence in accordance with the above basis.

## Validity

There is no time limit.  
When using this document the up-to-dateness of above basis and the conformity of the product have to be observed.

The data and results given relate solely to the tested and described specimen. This test does not allow any statement to be made on further characteristics of the present structure regarding performance and quality.

## Notes on publication

The ift-Guidance Sheet "Conditions and Guidance for the Use of ift Test Documents" applies.

## Identity-Check



[www.ift-rosenheim.de/ift-geprueft](http://www.ift-rosenheim.de/ift-geprueft)  
ID: 25B-3BED2

## Summary of results

Assessment according to ift-Guideline MO-01/1, section	Tested performance characteristics	Test results
5.4	Receiving inspection according to ift-Guideline MO-01/1:2007-01	Requirements fulfilled
	Watertightness in new condition following EN 1027:2016-03	No water penetration at up to 600 Pa
	Air permeability in new condition according to EN 12114:2000-03	$a < 0.1 \text{ m}^3/[\text{m}^*\text{h}^*(\text{daPa})^{2/3}]$
	Thermal cycling according to ift-Guideline MO-01/1:2007-01	Requirements fulfilled
	Mechanical durability following EN 1191:2000-02	Requirements fulfilled
	Resistance to wind load - alternating positive and negative pressures following EN 12211:2016-03	Requirements fulfilled
	Air permeability after load tests according to EN 12114:2000-03	$a < 0.1 \text{ m}^3/[\text{m}^*\text{h}^*(\text{daPa})^{2/3}]$
	Watertightness after load tests following EN 1027:2016-03	No water penetration at up to 600 Pa
	Dismantling and inspection according to ift-Guideline MO-01/1:2007-01	Requirements fulfilled

**The test specimen fulfils the requirements of ift-Guideline MO-01-1:2007-01, section 5.4 within the scope: Internal and external**